

एन यू पी पी एल



नेयवेली उत्तर प्रदेश पावर लिमिटेड
NEYVELI UTTAR PRADESH POWER LIMITED

(एन एन सी इंडिया लिमिटेड एवं यू पी राज्य विद्युत उत्पादन निगम लिमिटेड का संयुक्त उपक्रम)
(A JOINT VENTURE OF NLC INDIA LTD. & UP RAJYA VIDYUT UTPADAN NIGAM LTD.)
घाटमपुर थर्मल पावर प्रोजेक्ट साइट आफिस, लहुरीमऊ गाँव के पास-काशिमपुर, तहसील-घाटमपुर
समूहि (झाकबर)-208001, जिला कानपुर नगर, उत्तर प्रदेश
GHATAMPUR THERMAL POWER PROJECT
NEAR VILLAGE LAHURIMAL - KASIMPUR, GHATAMPUR TEHSIL, P.O.: SAMUHI-208001,
KANPUR NAGAR DISTRICT, UTTAR PRADESH
CIN: U40300UP2012GOI053569, GSTIN: 09AAECN3221E1ZS
E-Mail: ceo.nuppl@nclindia.in, ts.nuppl@nclindia.in



Lr. No. CEO/NUPPL/MoEF&CC/EC/024/2022/1512

Date- 11/08/2022

To,
The Scientist 'F',
Ministry of Environment, Forest and Climate Change,
Indira Paryavaran Bhawan,
Jorbagh, New Delhi-110003,

Kind Attention: Shri. Y.P. Singh

Sub: Submission of Six Monthly Compliance Report to Environment Clearance for the Ghatampur Thermal Power Project (3 X 660 MW)– Reg.

Ref: 1) Environment Clearance No J-13012/113/2011-IA II (T) Dt.17.06.2015 from MoEF, GOI

Sir,

Please find enclosed herewith Six Monthly Compliance Status Report for the General and Specific Conditions mentioned in the Environmental Clearance(Ref.1) – Period: Jan-2022 to June-2022 for your kind information and records.

Thanking you and with regards.

Yours Sincerely,

(Santosh C.S)

Chief Executive Officer
Neyveli Uttar Pradesh Power Ltd.

Encl.: As Above.

Lr. No. CEO/NUPPL/MoEF&CC/EC/024/2022/1512 of dated: 11/08/2022

Copy forwarded to the following for information and necessary action:

- 1) Regional office, MoEF&CC, Kendriya Bhawan, 5th Floor, Sector H, Aliganj, Lucknow, Uttar Pradesh-260224 (email: rcoz.lko-mef@nic.in).
- 2) Chief Environment Officer (Circle - 2), U.P. Pollution Control Board, Building No. TC-12V, Vibhuti Khand, Gomti Nagar, Lucknow-226010 (email: ceo2@uppcb.com).
- 3) The Regional Officer, U.P. Pollution Control Board, 243, Avas Vikas, Phase III, Sadbhavna Nagar, Kalyanpur, Kanpur-208017 (Email: rokanpur@uppcb.com).

(Santosh C.S)

Chief Executive Officer
Neyveli Uttar Pradesh Power Ltd.

**SIX MONTHLY COMPLIANCE REPORT OF
ENVIRONMENTAL CLEARANCE**



3 X 660 MW GHATAMPUR THERMAL POWER PROJECT

**NEAR VILLAGE LAHURIMAU-KASIMPUR,
GHATAMPUR TEHSIL, P.O.: SAMUHI-208001,
DISTRICT-KANPUR NAGAR (UTTAR PRADESH)**

Submitted to:

**MOEF&CC, NEW DELHI
REGIONAL OFFICE OF MOEF&CC, LUCKNOW
CENTRAL POLLUTION CONTROL BOARD (CPCB), LUCKNOW.
U P POLLUTION CONTROL BOARD, LUCKNOW.**

Submitted by:

**NEYVELI UTTAR PRADESH POWER LIMITED
(A JOINT VENTURE OF NLC INDIA LTD. & UP RAJYA VIDYUT UTPADAN NIGAM LTD.)**

*Regd. Office: KH 419, G.N. Extension,
Gomti Nagar, Lucknow-226010 (U.P.)-Tele Fax:0522-4951065*

(Period: JAN 2022 - JUNE 2022)

**Ghatampur Thermal Power Project (3 X 660 MW), NEAR VILLAGE LAHURIMAU-KASIMPUR,
GHATAMPUR TEHSIL, KANPUR NAGAR DISTRICT, UTTAR PRADESH**

SIX MONTHLY COMPLIANCE STATUS OF ENVIRONMENTAL CLEARANCE CONDITIONS

VIDE LETTER NO J-13012/113/2011-IA II (T) DT.17.06.2015

Sl. No.	ENVIRONMENTAL CLEARANCE CONDITIONS	Compliance Status as on 30.06.2022
A	Specific Conditions	
i	Latest authenticated satellite imagery shall be submitted on an annual basis to monitor the alterations of the area.	Noted. Google Earth project area image submitted vide Lr. No. CEO/NUPPL/MoEF&CC/003/2021/1027 Dt. 11.01.2021
ii	The Guidelines for import of coal, as and when notified by the concerned Authority, shall be complied with.	Coal will not be imported for the project and same was communicated via email dt. 21.08.2021 vide attached Lr. no. CEO/NUPPL/MoEF&CC/EC/012/2021/1257 DT. 21/08/2021 with the ministry.
iii	The Sulphur and ash content of coal shall not exceed 0.45 % and 6% respectively. In case of variation of quality at any point of time, fresh reference shall be made to the ministry for suitable amendments to the environmental clearance.	Coal will not be imported for the project. 100% Domestic coal will be used. The Sulphur and Ash content of the domestic coal may vary from the said limits and same will be communicated with the ministry in separate letter.
iv	The coal transportation shall be by rail only.	The said stipulation will be complied during operation phase of the project. However, the Railway Siding construction work is under progress.
v	As committed a minimum amount of 0.4% and 0.08% of the capital cost of the project shall be earmarked as capital cost during the construction phase of the project and recurring cost per annum till the operation of the plant respectively for CSR activities.	An amount of Rs. 68.95 Cr. has been earmarked for implementing CSR activities during construction phase of the project. Total amount spent till June 2022 is Rs. 20.76 Cr. The following CSR activities conducted for Project affected villages like Mobile Health Care Camps, Sponsoring Candidates for

Sign
EE/Environment
NUPPL

T. Chandra
DGM/TS
NUPPL


		<p>Skill Development Courses, Construction of Bore holes and Hand pumps (Phase I), solar panels with inverter, Water Supply distribution pipe line, renovation of School Buildings, construct a Wash room for women police station, Installation and commissioning of water coolers, Conducted Integrated village development program Art of Living, Installation of Solar streetlight. Various activity related to COVID-19 has been done which are follows: 1. Helping in setting up COVID Lab in GSVM Medical College. 2. Financial assistance provided to purchase one RNA extractor machine. 3. Renovation of COVID ward No 1,2,3,4 at Hallet Hospital.</p> <p>Following activities are under tendering and planning stage-</p> <ol style="list-style-type: none"> 1. Installation and commissioning of 50 nos. of solar submersible pump. 2. Installation and commissioning of 2000 nos. of solar street light. 3. construction of toilet block near CC road of GTPP entrance. 4. Construction of cook house and dining room in NCC area of Kanpur division. 5. Shed construction and drinking water facilities in Deputy Labour Commissioner office for the welfare of labours.
<p>Vi</p>	<p>CSR schemes identified based on need based assessment shall be implemented in consultation with the village Panchayat and the District Administration starting from the development of project itself. As part of CSR prior identification of local employable youth</p>	<p>All CSR works are being carried out on recommendation of District Administration. Also, suggestions of Members of Legislative Assemblies and Parliament and local panchayat are taken. CSR works are being</p>

Signatures
 EE/Environment
 NUPPL

Signature
 DGM/TS
 NUPPL

	and eventual employment in the project after imparting relevant training shall be also undertaken.	carried out for local area welfare. In future same will be followed. Approval from the Board of Directors NUPPL has been obtained for skill development and MoU with UP Skill Development Mission is under progress for providing training to 500 local employable youth.
vii	For proper and periodic monitoring of CSR activities, a CSR committee or a Social Audit committee or a suitable credible external agency shall be appointed. CSR activities shall also be evaluated by an independent external agency. This evaluation shall be both concurrent and final.	Board level CSR Committee has already been constituted in the Year 2018. Member of CSR committee till march 2022 were 1. Shri. Ajit Kumar Tewary. 2. Shri. Shaji John. 3. Shri. Jaykumar Shrinivasan. Identification of external agencies for monitoring of CSR program of NUPPL is being planned and under progress.
viii	FGD shall be provided to minimize the SO2 emissions.	Bid submitted and Tender Evaluation is under progress. The said stipulation will be complied.
ix	Vision document specifying prospective plan for the site shall be formulated and submitted to the Regional Office of the Ministry within six months.	Complied.
x	Harnessing solar power within the premises of the plant particularly at available roof tops shall be carried out and status of implementation including actual generation of solar power shall be submitted along with half yearly monitoring report.	Noted. Tendering process for award of the contract is in advance phase.
xi	A long-term study of radio activity and heavy metals contents on coal to be used shall be carried out through a reputed institute and results thereof analyzed every two year and reported along with monitoring reports. Thereafter mechanism for an in-built continuous monitoring for radio activity and	The same said stipulation will be complied during operation phase of the plant.


 EE/Environment
 NUPPL


 DGM/TS
 NUPPL

	heavy metal in coal and fly ash (including bottom ash) shall be put in place.	
xii	A stack of 275 m height shall be provided with continuous online monitoring equipment's for SOx, NOx and PM2.5 & PM 10. Exit velocity of flue gases shall not be less than 22 m/ sec. mercury emissions from stack shall also be monitored on periodic basis.	Construction of chimney shell till 275 mtr. is completed. Unit 1 & Unit 2 Flue Gas Can construction completed. Duct connection for Unit 2 and Flue Can fabrication for Unit 3 is under progress. The other said stipulation will be complied during operation phase of the plant.
xiii	High Efficiency Electrostatic precipitators (ESPs) shall be installed to ensure that particulate emission does not exceed 50 mg/ Nm3 Adequate dust extraction systems such as cyclones /bag filters and water spray systems in dusty areas such as in coal handling and ash handling points, transfer areas shall be provided.	High Efficiency Electrostatic precipitators (ESPs) are under construction. The other said stipulation will be complied during operation phase of the plant.
xiv	Adequate dust extraction systems such as cyclones / bag filters and water spray systems in dusty areas such as in coal handling and ash handling points, transfer areas and other vulnerable dusty areas shall be provided.	<p>1) Adequate dust extraction system will be provided along with bag filter at Coal handling plant at different locations (Crusher House, Unit 1,2,3 Bunker)</p> <p>2) Dry fog dust suppression system (DFDS) will be provided at all receiving/discharge chutes at CHP.</p> <p>3) Stock pile dust suppression (SPDS) system will be provided at all coal stock piles to suppress the dust.</p> <p>4) Adequate dust extraction system will be provided along with bag filter at Ash handling plant at different locations (ESP, Ash silo)</p> <p>5) Rotary ash conditioner will be provided at ash silo to suppress the fine dust at AHP.</p>
xv	COC of at least 5.0 shall be adopted.	Circulating water system work under progress. NDCT (Natural Draught cooling tower) work under progress. 01 no. NDCT

Sigim
 EE/Environment
 NUPPL


Thakur
 DGM/TS
 NUPPL

		for each unit. The CW system is proposed to operate at 5 cycles of concentrations.
xvi	Monitoring of surface water quantity and quality shall also be regularly conducted and records maintained. The monitored data shall be submitted to the ministry regularly. Further, monitoring points shall be located between the plant and drainage in the direction of flow of ground water and records maintained. Monitoring for heavy metals in ground water shall also be undertaken and results/ findings submitted along with half yearly monitoring report.	The same said stipulation will be complied during operation phase of the plant.
xvii	A well-designed rain water harvesting system shall be put in place within six months, which shall comprise of rain water collection from the built up and open area in the plant premises and detailed record kept of the quantity of water harvested every year and its use.	Scope of rain water harvesting system is added in work contract (GA3 package). The same said stipulation will be complied.
xviii	No water bodies including natural drainage system in the area shall be disturbed due to activities associated with the setting up/ operation of the power plant.	The said stipulation is being complied.
xix	Hydrogeology of the area shall be reviewed annually from an instate/ organization of repute on surface water and ground regime (especially around ash dyke). In case any deterioration is observed specific mitigation, measures shall be undertaken and reports/ data of water quality monitored regularly and maintained shall be submitted to the regional office of the ministry.	The same said stipulation will be complied during operation phase of the plant.
xx	Wastewater generated from the plant shall be treated before discharge to comply limits prescribed by the SPCB/ CPCB.	Construction of Effluent Treatment Plant work in progress and the said stipulation will be complied during operation phase of the plant. Work is under progress.

Sign
EE/Environment
NUPPL

J. K. S.
DGM/TS
NUPPL

xxi	Additional soil for leveling of the proposed site shall be taken from within the sites (to the extent possible) so that natural drainage system of the area is protected and improved.	Noted. All the soil and earth material is being utilized within the plant premises only with all necessary precautions to protect natural drainage system of the area.
xxii	Fly ash shall be collected in dry form and storage facility (silos) shall be provided for the same. Unutilized fly ash shall be disposed off in the ash pond in the form of slurry. Mercury and other heavy metals (As, Hg, Cr, Pb. etc.) will be monitored in the bottom ash as also in the effluents emanating from the existing ash pond. No ash shall be disposed off in low lying area.	The said stipulation will be complied during operation phase of the plant.
xxiii	Fugitive emission of fly ash (dry or wet) shall be controlled so that no agricultural or non- agricultural land is affected. Damage to any land shall be mitigated and suitable compensation shall be provided in consultation with the local Panchayat.	The said stipulation will be complied during operation phase of the plant.
xxiv	Ash pond shall be lined with HDPE/LDPE lining or any other suitable impermeable media so that no leachate takes place at any point of time adequate safety measure shall also be implemented to protect the ash dyke from getting breached.	Construction of ash pond along with HDPE lining work under progress. The said stipulation will be complied. Work is under progress.
xxv	Green belt consisting of three tiers of plantations of native species around plant and at 50 m width shall be raised after providing adequate justification to the ministry. Tree density shall not be less than 2500 per hectare with survival rate not less than 80%.	Noted. Mass tree plantation of native species around the plant are being taken up frequently to develop the Greenbelt area as per as per stipulated conditions.
xxvi	Green belt shall also be developed around the Ash pond over and above the Green belt around the plant boundary.	The same will be complied as per said stipulations.
xxvii	An Environmental cell comprising of at least one expert in environmental science/ engineering, Ecology, Occupational Health and social science shall be created preferably at the project site itself and shall	NUPPL Environment Cell is headed by a Dy. General Manager level officer directly reporting the Plant Head. Also, the


EE/Environment
NUPPL


DGM/TS
NUPPL

	be headed by an officer of appropriate superiority and qualification. It shall be ensured that the head of the cell shall directly report to the head of the plant who would be accountable for implementation of environmental regulations and social impact improvement/ mitigation measures.	Environment Cell consist of a Environment Engineer.
B	General Conditions	
i	The treated effluents conforming to the prescribed standards only shall be re-circulated and reused within the plant. Arrangements shall be made that effluents and storm water do not get mixed.	Construction of Effluent Treatment Plant as per the standards is in progress and the said stipulation will be complied with during operation phase of the project.
ii	A sewage treatment plant shall be provided (as applicable) and the treated sewage shall be used for raising green belt/ plantation.	Construction of STP in the plant is under progress. Also, a 600 KLD STP separately for the township had been installed and is operational. The treated sewage conforming to prescribed standards are being utilized for plantation & raising greenbelt areas.
iii	Adequate safety measures shall be provided in the plant area to check / minimize spontaneous fires in coal yard, especially during summer season. Copy of these measures with full details along with location plant layout shall be submitted to the ministry as well as to the regional office of ministry.	Noted. Construction of fire system is under progress. Also, installation of Dust Suppression System is under progress.
iv	Storage facilities for auxiliary liquid fuel such as LDO/HFO/LSHS shall be made in the plant area in consultation with department of Explosives, Nagpur, Sulphur content in the liquid fuel will not exceed 0.5%. Disaster Management Plan shall be prepared to meet any eventuality in case of an accident taking place due to storage of oil.	License for storage of 5775.20 KL LDO (Petroleum Class-C product) had been obtained from O/o Chief Controller of Explosive, Nagpur. vide letter dated: 09-06-2021. Hazop Study Report prepared for the plant.
v	First Aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.	Complied. All arrangements related to first aid and sanitation for workers/drivers during construction phase of the project are under the scope of EPC contractor. However,

Sign
EE/Environment
NUPPL

Sign
DGM/TS
NUPPL

		NUPPL monitors effective compliance of the said stipulations.
vi	Noise levels emanating from turbines shall be so controlled such that the noise in the work zone shall be limited to 85 dB(A) from source for people working in the high noise area, requisite personal protective equipment like earplug/ ear muffs etc. shall be provided. Workers engaged in noisy areas such as turbine area, air compressor etc. shall be periodically examined to maintain audiometric record and for treatment for any hearing loss including shifting to non-noisy/ less noisy areas.	The said stipulation will be complied during operation phase of the plant.
vii	Regular monitoring of ambient air ground level concentration of SO ₂ , NO _x , PM _{2.5} & PM ₁₀ and Hg shall be carried out in the impact zone and records maintained. if at any stage these levels are found to exceed the prescribed limits, necessary control measures shall be provided immediately. The location of the monitoring stations and frequency to monitoring shall be decided in consultation with SPCB. Periodic reports shall be submitted to regional office of this ministry. The data shall also be put on the website of the company.	NOC for installation of 04 nos. of AAQMS was received from Regional Office, UP Pollution Control Board, Kanpur vide letter dated 05/02/2021. Material order has been placed. Installation and commissioning will be completed before COD.
viii	Utilization of 100% fly Ash generated shall be made from 4 th year of operation, Status of implementation shall be reported to the regional office of the ministry.	The said stipulation will be complied during operation phase of the plant.
ix	Provision shall be made for the housing of construction labour (as applicable) within the site with all necessary infrastructure and facilities such as fuel for cooking, mobile toilets, mobile STP, safe drinking water medical health care crèche etc. the housing may be in the form of temporary structures to be removed after the completion of the project.	Labour colonies with necessary infrastructure facilities such as housing, sanitation, mobile toilet, fuel, medical facilities, safety, drinking water supply etc. is being provided for construction labours through EPC contractors. NUPPL monitors for effective compliance of the said stipulation by the contactors.

[Signature]
EE/Environment
NUPPL

[Signature]
DG/MTS
NUPPL

x	The project proponent shall advertise in at least two local newspapers widely circulated in the region around the project , one of which shall be in the vernacular language of the locality concerned within seven days from the date of this clearance letter informing that the project has been accorded environmental clearance and copies of clearance letter are available with the state pollution control board/ committee and may also be seen at website of the ministry of Environment and forests at http://envfor.nic.in .	Complied. The information of Environment Clearance was advertised in local newspapers i.e. Amar Ujala, Hindustan Times and Pioneer.
xi	A copy of the clearance letter shall be sent by the proponent to concerned Panchayat, Zila parisad/ Municipal corporation, urban local body and the local NGO, if any, from whom suggestions/ representations, if any, were received while processing the proposal. The clearance letter shall also be put on the website of the company by the proponent.	Complied. Copy of clearance letter had been already submitted to Village Pradhan and local body.
xii	The proponent shall upload the status of compliance of the stipulated environmental clearance conditions, including results of monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the regional office of MOEF, the respective Zonal office of CPCB and the SPCB the criteria pollutant levels namely; SPM RSPM (PM2.5 & PM10), SO2, NOx (ambient levels as well as stack emissions) shall be displayed at a convenient location near the main gate of the company in the public domain.	Noted. The said stipulation will be complied. Analyzer for SO2, NOX has been received at site. SPM analyzer procurement is under progress. Installation and commissioning will be completed before COD.
xiii	The environment statement for each financial year ending 31 st march in from-V as is mandated to be submitted by the project proponent to the concerned state pollution control Board as prescribed under the	The said stipulation will be complied after operation of the plant.

Sign
EE/Environment
NUPPL

J. K. Singh
DGM/TS
NUPPL

	Environment (protection) rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of environmental clearance conditions and shall also be sent to the respective regional officers of the ministry by e-mail.	
xiv	The project proponent shall submit six monthly reports on the status of the implementation of the stipulated environmental safeguards to the ministry of environmental and forests its regional office, central pollution control board and state pollution control board the project proponent shall upload the status of compliance of the environment clearance conditions on their website and update the same periodically and simultaneously send the same by e-mail to the regional office ministry of environment and forests.	Noted. The Six-monthly Environment clearance compliance report is being submitted periodically to Ministry of Environmental and Forests, its Regional Office, Central Pollution Control Board and State Pollution Control Board.
xv	Regional office of the ministry of environment & forests will monitor the implementation of the stipulated conditions. A complete set of documents including environmental impact Assessment report and environment management plan along with the regional information submitted from time to time shall be forwarded to the regional office for their use during monitoring project proponent will upload the compliance status in their website and up-date the same from time to time at least six-monthly basis. Criteria pollutants levels including Nox (from stack & ambient air) shall be displayed at the main gate of the power plant.	Noted. Environment management plan is being shared with regional office. The other said stipulation will be complied. Criteria pollutants levels including NOX (from stack and ambient air) will be displayed at the main gate of power plant. Procurement of instruments is under progress. Installation and commissioning will be completed before COD.
xvi	Separate funds shall be allocated for implementation of environmental protection measures along with item – wise break-up these costs shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be	Financial provision stipulated towards environmental protection measure will not be diverted for any other purpose. Year-wise expenditure will be shared with the ministry.

Sigis
EE/Environment
NUPPL

Shub
DG/TS
NUPPL

	diverted for other purposes and year-wise expenditure should be reported to the ministry.	
xvii	The project authorities shall inform the regional office as well as the ministry regarding the date of financial closure and final approval of the project by the concerned authorities and the dates of start of land development work and commissioning of plant.	Date of Project Approval by Gol: 27-07-2016. Date of Financial Closure: 22.06.2021 Project construction activities started with "Ground Breaking Ceremony" held on 20.10.2016 Anticipated COD Dates of Plant are – Unit I: 31.03.2023 Unit II: 31.07.2023 Unit III: 30.11.2023
xviii	Full co-operation shall be extended to the scientists/officers from the ministry / regional office of the ministry/ CPCB/SPCB who would be monitoring the compliance of environmental status.	Noted. Full co-operation is being extended to the Scientists/ Officers from the Ministry / Regional Office of the Ministry/ CPCB/ SPCB during monitoring the compliances of environmental status.
6	The Ministry reserves the right to revoke the clearance if conditions stipulated are not implemented to the satisfaction. The Ministry may also impose additional environmental conditions or modify the existing ones, if necessary.	Noted
7	The environmental clearance accorded shall be valid for a period of 7 years for the date of issue of this letter to start operations by the power plant.	Noted.
8	Concealing factual data or submission of false/fabricated data and failure to comply with any of the conditions mentioned above may result in withdrawal of this clearance and attract action under the provisions of Environment (Protection) Act, 1986.	Noted.
9	Incase of any deviation or alteration in the project proposed including coal transportation system from those submitted to this Ministry for clearance, a fresh reference should be made to the Ministry to assess	Noted.

Sign
EE/Environment
NUPPL

Signature
DGM/TS
NUPPL

	the adequacy of the condition(s) imposed and to add additional environmental protection measures, if any.	
10	The above stipulations would be enforced among others under the Water (Prevention and Control of Pollution) Act 1974, the Air (Prevention and Control of Pollution) Act 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management, handling & Transboundary Movement) Rules, 2008 and its amendments, the Public Liability Insurance Act, 1991 and its amendments.	Noted.
11	Any appeal against this environmental clearance shall lie with the National Green Tribunal, if preferred, within 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.	Noted.


11/8/2020

(Santosh C.S)

(Chief Executive Officer)

Neyveli Uttar Pradesh Power Ltd.



VISION DOCUMENT

Neyveli Uttar Pradesh Power Limited

(3 X 660 MW) Ghatampur Thermal Power Station - GTPS

VISION

“To emerge as a leading Power Company in the State of Uttar Pradesh and continue to be socially responsive”.

MISSION

- i. Strive towards greater cost competitiveness and work towards continued financial strength;
- ii. Continually imbibe best practices from the best Indian and International Organisation and also adopt environment-friendly technologies for Power Generation;
- iii. Be a preferred Employer by offering attractive avenues of career growth and excellent work environment and by deploying human resources to match International standards;
- iv. Play an active role in society and to be sensitive to emerging environmental issues.

Print Back



भारत सरकार
Government of India
वाणिज्य और उद्योग मंत्रालय
Ministry of Commerce & Industry
पेट्रोलियम तथा विस्फोटक सुरक्षा संगठन (पैसो)
Petroleum & Explosives Safety Organisation (PESO)
63/4, ए-विंग, दूसरा तल, केंद्रालय (सी.जी.ओ. काम्प्लेक्स), संजय प्लेस
आगरा- 282002
63/4, A-Wing, IInd floor, Kendralaya (CGO Complex), Sanjay Place,
Agra - 282002

E-mail : jtcceagra@explosives.gov.in

Phone/Fax No : 0562 - 2523244,2523266

संख्या /No. : P/CC/UP/15/5099 (P495237)

दिनांक /Dated : 09/06/2021

सेवा में
/To,

M/s. NEYVELI UTTAR PRADESH POWER LIMITED,
Ghatampur Thermal Power Project Site Office,
Near Village Lahurimau-Kasimpur, Ghatampur Tehsil,,

Taluka: Ghatampur,
District: KANPUR NAGAR,
State: Uttar Pradesh
PIN: 208001

विषय /Sub: Khasra No, 301to304,305G,306,307K,308,309,311Kh,312,313,314K, Village- LAHURIMAU KASIMPUR Part-1,, LAHURIMAU KASIMPUR Part-1, Ghatampur, Taluka: Ghatampur, District: KANPUR NAGAR, State: Uttar Pradesh, PIN: 208001 में पेट्रोलियम वर्ग C का अधिष्ठापन -अनुज्ञप्ति जारी करने के बारे में ।
Petroleum Class C Installation at Khasra No, 301to304,305G,306,307K,308,309,311Kh,312,313,314K, Village- LAHURIMAU KASIMPUR Part-1,, LAHURIMAU KASIMPUR Part-1, Ghatampur, Taluka: Ghatampur, District: KANPUR NAGAR, State: Uttar Pradesh, PIN: 208001 Grant of License regarding.

महोदय
/Sir(s),

कृपया आपके पत्र क्रमांक OIN798334 दिनांक 09/06/2021 का अवलोकन करें ।

Please refer to your letter No. OIN798334 dated 09/06/2021

विषयान्तर्गत अधिष्ठापन में निम्नलिखित पेट्रोलियम पदार्थों के वर्ग तथा मात्रा के भंडारण के लिए पेट्रोलियम नियम, 2002 के अधीन प्ररूप - XV में स्वीकृत, दिनांक 31/12/2030 तक वैध अनुज्ञप्ति संख्या P/CC/UP/15/5099 (P495237) दिनांक 09/06/2021 भेजी जा रही है ।

Licence No. P/CC/UP/15/5099 (P495237) dated 09/06/2021 granted in Form XV under the Petroleum Rules, 2002 and valid till 31/12/2030 for the storage of the following kinds and quantities of Petroleum at the subject installation is forwarded herewith.

पेट्रोलियम का विवरण /Description of Petroleum	किलोलीटरों में अनुज्ञप्त क्षमता /Quantity licenced in KL
वर्ग क प्रपुंज पेट्रोलियम /Petroleum Class A in bulk	NIL
वर्ग क प्रपुंज पेट्रोलियम से भिन्न /Petroleum Class A, otherwise than in bulk	NIL
वर्ग ख प्रपुंज पेट्रोलियम /Petroleum Class B in bulk	NIL

वर्ग ख प्रपुंज पेट्रोलियम से भिन्ना /Petroleum Class B, otherwise than in bulk	NIL
वर्ग ग प्रपुंज पेट्रोलियम /Petroleum Class C in bulk	5775.20 KL
वर्ग ग प्रपुंज पेट्रोलियम से भिन्ना /Petroleum Class C, otherwise than in bulk	NIL
<hr/>	
कुल क्षमता /Total Capacity	5775.20 KL
<hr/>	

कृपया पेट्रोलियम नियम 2002 के अधीन बनाए गए नियम 148 में दी गई प्रक्रिया का कडाई से पालन करें और अनुज्ञप्ति के नवीकरण हेतु समस्त दस्तावेजों को अनुज्ञप्ति की वैधता समाप्ति की तारीख या उससे पूर्व **Jt. Chief Controller of Explosives, AGRA** को प्रेषित करें।

Please follow the procedure strictly as laid down in rule 148 of the Petroleum Rules, 2002 and submit complete documents for the Renewal of the licence to **Jt. Chief Controller of Explosives, AGRA**, so as to reach his office on or before the date on which Licence expires.

यह अनुमोदन/ अनुमति अन्य प्राधिकारियों से आवश्यक अनुमति/क्लीयरन्स प्राप्त करने से या यथा लागू अन्य विधियों से छूट नहीं देती है।

This approval/permission, however, does not absolve from obtaining necessary permission/clearance from other authorities or under other statutes as applicable.

भवदीय /Yours faithfully,

((डा.ए.पी.सिंह)
(Dr. A.P. Singh))
संयुक्त मुख्य विस्फोटक नियंत्रक
Jt. Chief Controller of Explosives
आगरा/Agra

Copy forwarded to :-

1. The Additional District Magistrate, KANPUR NAGAR(Uttar Pradesh) with reference to his NOC No 2064 Dated 29/05/2021

Jt. Chief Controller of Explosives
Agra

(अधिक जानकारी जैसे आवेदन की स्थिति, शुल्क तथा अन्य विवरण के लिए हमारी वेबसाइट <http://peso.gov.in> देखें)
(For more information regarding status, fees and other details please visit our website <http://peso.gov.in>)

Note:-This is system generated document does not require signature.

Disclaimer : This page gives the latest action taken by this organization on your application. This page is made available for the information of concerned applicant/licensee only. All efforts have been made to secure this information. However, PESO will not be responsible for any misuse of the information by unauthorized persons including the hackers.



क्षेत्रीय कार्यालय : 30प्र0 प्रदूषण नियंत्रण बोर्ड, कानपुर
REGIONAL OFFICE : U.P. POLLUTION CONTROL BOARD, KANPUR

संदर्भ 1178/NUPC-54/2)
सेवा में,

दिनांक 5/2/21

नेयवेली उत्तर प्रदेश पावर लिमिटेड,
घाटमपुर थर्मल पावर प्रोजेक्ट साइट आफिस,
लहरीमऊ गाँव के पास-काशिमपुर, तहसील-घाटमपुर,
कानपुर।

विषय:-NUPPL-3X660 MQ-Finalization of locations of Ambient Air Quality Monitoring System for GTPP.

महोदय,

कृपया उपरोक्त विषयक आपके पत्रांक CEO/NUPPL/UPPCB/AAQMS/002/2020 दिनांक 07.12.2020 का सन्दर्भ ग्रहण करने का कष्ट करें। पत्र के माध्यम से 04 नग Ambient Air Quality Monitoring System की स्थापना हेतु स्थल हेतु इस कार्यालय की सहमति चाही गयी है। आपके द्वारा प्रस्तावित स्थल Ambient Air Quality Monitoring System हेतु उपयुक्त है:-

Proposed Locations of AAQMS Installation			
Sl.No.	Item	Co-ordinates	
		Latitude	Longitude
1	Location No. 1 (GTPP)	25°57'53.32"N	80°11'9.82"E
2	Location No. 2 (Infront Estate office Township)	25°59'20.64"N	80°9'35.71"E
3	Location No. 3 (Hamirpur)	25°57'46.93"N	80°08'46.74"E
4	Location No. 4 (Near Sirsa Village)	25°59'06.7"N	80°12'05.0"E

अग्रतर यह अपेक्षित है कि लोकेशन नं०-1 व 3 पर जन सामान्य के हित में डिस्ट्रिक्ट बोर्ड स्थापित किये जाये।

भवदीय

Signature
05/02/2021
(डॉ० ए०के० माथुर)
क्षेत्रीय अधिकारी